

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-0531:103

Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Victaulic Co. of America, PO Box 31, Easton PA 18042-0031  
Contact: Mike John \*(610) 559-3300 \*Fax (610) 923-3095

**DESIGN:** Models 708 (8") and 708W (2", 2-1/2", 3", 4", 5", 6", 8", 10" and 12") series butterfly valves. For above ground use only. Models 708W valves are suitable for outdoor use. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, UL and FM label.

**APPROVAL:** Listed as above ground water control valves for fire protection service.

\*Rev. 08-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager